



Fair  
Trading

Ref: CS11124/1

## ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11124N Particulars of Modification(s)

Model No. PWS2-30P-EX being similar to approved Model No. PWS2-29P-EX except for:

**AC terminal (Grid model):**

Rated input/output current: 43.3Aa.c

Maximum continuous input/output current: 47.6Aa.c

Rated input/output apparent power: 30kVA

Maximum input/output apparent power: 33kVA

**AC terminal (Stand-alone model):**

Rated current: 43.3Aa.c

Maximum continuous current: 47.6Aa.c

Rated apparent power: 30kVA

Maximum apparent power: 33kVA

This certificate will expire on 14/10/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:  
14 October 2022

14 October 2022

For Secretary, Department of Customer Service